Wrightsville Wastewater Utility

Residential or Commercial Building Sewer Connection Permit

NAME: _____

STREET ADDRESS: _____

LOT/BLOCK/SUBDIVISION: _____

____ SINGLE FAMILY RESIDENCE

____ MULTI-FAMILY RESIDENTIAL NUMBER OF UNITS: _____

____ COMMERCIAL OTHER _____ ____ WATER METER SIZE _____

SEWER LINE INSTALLATION BY: _____ M# _____

ADDRESS: _____

GENERAL CONTRACTOR: _____

ADDRESS: _____

IN CONSIDERATION OF THE GRANTING OF THIS PERMIT THE UNDERSIGNED AGREES:

TO ACCEPT AND ABIDE BY ALL PROVISIONS OF THE WRIGHTSVILLE WASTEWATER UTILITY "SPECIFICATION REQUIREMENTS FOR SANITARY SEWERS", LATEST REVISION.

TO MAINTAIN THE BUILDING SEWER AT NO EXPENSE TO THE UTILITY, TO THE POINT OF CONNECTION WITH THE PUBLIC SEWER MAIN.

TO NOTIFY THE UTILITY'S INSPECTOR BY CALLING (501) 897 - 4547 WHEN THE BUILDING SEWER IS READY FOR INSPECTION AND CONNECTION TO THE PUBLIC SEWER MAIN, BUT BEFORE ANY PORTION OF THE WORK IS COVERED.

FEE(S)	RECEIPT NUMBER(S)	
CONNECTION FEE	$ _____	# _____
INSPECTION FEE	$ _____	# _____
SERVICE DEPOSIT	$ _____	# _____
TAP CHARGE	$ _____	# _____
TOTAL FEES	$ _____	

APPLICANT: SIGNED: _____

____ PLUMBING CONTRACTOR ____GENERAL CONTRACTOR ____OWNER

APPROVED BY: _____ DATE: _____

THE CITY OF WRIGHTSVILLE , ARK
Sewer Line Connection Check List

1. All persons performing plumbing work within the district must be properly licensed through the Arkansas Department of Health. Exception: Homeowners may do plumbing work on their own residence provided local permits and local licenses are obtained, the plumbing is installed according to Arkansas State Plumbing Code Standards, and inspected by a certified Wrightsville, Ark. plumbing inspector. Arkansas State Law 412 & 330 of 1991, Sec 17-31- 302

2. The installer shall use SDR 40 PVC pipe approved by ASTM. All joints shall be glued with PVC glue or approved rubber gaskets installed in the joints and primed using blue primer on on the pipe.

3. A clean out shall be installed within 3 to 5 foot of the outside walls and every 100 foot thereafter.

4. All sewer pipe shall be completely bedded in the trench with loose dirt. sewer and water lines may not be placed in the same trench and said trenches must be at lease 10 feet apart.

5. Connection to the sewer main shall be made to the existing wye's in the main line or stubouts in the manholes where available. when it is necessary to tap into the main line a saddle wye connection shall be used which completely covers the tapped hole in the main line and is attached to the main by two hose clamps which completely circle the main line to hold the saddle in place.the saddle shall have a rubber gasket to seal the tapped hole in the main and shall be glued with PVC glue.

6. The line shall be laid on a minimum grade of 1/8 inch per foot. sewer lines shall be laid at a minimum depth of 18 inches below natural ground level.

7. Leave all pipe, joints, taps, wye's uncovered until the inspection has been completed and approved. DO NOT COVER ANY WORK UNTIL AFTER INSPECTION.

8. A $25.00 inspection fee shall be presented to the Wrightsville Plumbing Inspector upon inspection of the sewer connection. if the installation is not approved a charge of $25.00 will be levied for each additional inspection .

9. The Wrightsville Plumbing Inspector has the right and power to reject any installation they determine to be unsatisfactory. THE PLUMBING INSPECTOR MUST BE GIVVEN A MINIMUM OF 2 WORKING DAYS NOTICE FOR AN INSPECTION.